

2016 Annual Drinking Water Quality Report
Town of Stanley
PWS ID # 01-36-035

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies.

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metal, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The Town of Stanley purchases all of its drinking water from the CITY of Mt. Holly. The City of Mt. Holly is supplied by surface water from Mountain Island Lake located off N.C. Hwy. 273 in northeast Gaston County. All water treatment is done by the City of Mt. Holly and distributed by the Town of Stanley within the service area.

We routinely monitor for over 150 contaminants in your drinking water according to the Federal, State and local laws. The tables below list all of the contaminants that we detected in the last round of sampling for the particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. Unless otherwise noted, the data presented in the tables is from testing done January 1 through December 31, 2016.

The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Important Drinking Water Definitions

Not-Applicable (NA) - Information not applicable/ not required for that particular water system or for that particular rule

Non-Detects (ND) - Contaminant is not present at the level of detection set

Parts per million (PPM) or Milligram per liter (mg/L)- One part per million correspond to one minute in two years or a single penny in \$10,000

Parts per billion (ppb) or Micrograms per liter (ug/L)- One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000

Parts per trillion (ppt) or Nanograms per liter (Nanograms/L)- One part per trillion corresponds to one minute in 2,000,000 years or a single penny in \$10,000,000,000

Parts per quadrillion (ppq) or Pictograms' per liter (pictograms/L)- One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the of the radioactivity in water

Million Fibers per liter (MFL) - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirement which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfection Level Goal(MRDLG)- The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Extra Note: MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the describe health effect.

Microbiological Contaminants

Contaminant (units)	MCL Violation	Your Water	MCLG	MCL	Likely Source
Total Coli form (Presence or absent)	NO	0	0	0	Naturally present in the environment
Fecal Coli form (Presence or absent)	NO	0	0	0	Human and animal fecal waste

Lead and Copper Contaminants (units)

Contaminants (units)	Sample Date	Your Water	# of sites above AL	MCLG	MCL	Likely Source
Copper (ppm) (90 percentile)	9/18/14	0.08	0	1.3	AL=1.3	Corrosion of household plumbing
Lead (ppb) 90 th percentile)	9/18/14	0.001	0	0	AL=15	Corrosion of household plumbing

If present elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from metals and components associated with service lines and home plumbing. The Town of Stanley is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or www.epa.gov/safewater/lead.

Asbestos Contaminant

Contaminant (units)	Sample Date	MCL Violation	Your Water	Range	MCLG	MCL	Likely Source
Total Asbestos (MFL)	6/20/12	NO	ND	N/A	7	7	Decay of asbestos cement water mains; Erosion of natural deposits

Disinfectants and Disinfection Byproducts Contaminants

Contaminants (Units)	MCL/MRDL Violation	Your Water (RAA)	Range	MCLG	MCL	Likely Source
TTHM (ppb) (Total chlorination Trihalomethanes)	NO	0.044	.025- .052	N/A	.080	By-product of drinking water
HAA5 (ppb) (Total Haloacetic Acids)	NO	.023	.012-.031	N/A	.060	By-product of drinking water chlorination

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

All Contaminant Groups Below Sampled by City of Mt. Holly

Turbidity

Contaminant (units)	Treatment Technique (TT) Violation	Your Water	Treatment Technique (TT) Violation if	Likely Source
Turbidity (NTU) Highest single Measurement	NO	0.100 NTU	Turbidity >1NTU	Soil runoff
Turbidity (NTU) Lowest monthly (%) Meeting limits	NO	100%	Less than 95% monthly measurements <0.3 NTU	Soil Runoff

Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation	Your Water	MCLG	MCL	Likely Source
Arsenic (ppb)	9/8/16	NO	ND	0	10	Erosion of natural deposits; runoff from Orchards, glass, and Electronic production waste
Fluoride (ppm)	9/8/16	NO	.90	4	4	Water additive for Strong teeth

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems

Nitrate/ Nitrite Contaminants

Contaminants (units)	MCL Violation	Your Water	MCLG	MCL	Likely Source
Nitrate (as Nitrogen) (ppm)	NO	0.17	10	10	Runoff from fertilizer Use; leaching from Septic tanks, erosion Of natural deposits

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

If you have any questions concerning this report, contact city hall at 704-263-4779.

Consumer Confidence Report Certification Form

Water System Name: Town of Stanley

FWS ID#: 01-36-035 Report Year: 2016 Population Served: 3800

The community water system named above hereby confirms that all provisions under 40 CFR parts 141 and 142 requiring the development of, distribution of, and notification of a consumer confidence report have been executed. Further, the CWS certifies the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primacy agency by their NC certified laboratory.

Certified by: Name: Alex Stewart II Title: ORC

Signature: 

Phone #: 704-860-8527 Date: 5-23-17

Check methods used and complete:

Systems serving 100,000 or more persons must post the CCR on a publicly-accessible Internet site which is www.

Systems serving 10,000 or more persons must distribute the CCR by mail or direct delivery.
Date Delivered: _____ and specify direct delivery methods: _____

Systems serving less than 10,000 persons but more than 500 persons must either distribute the CCR by mail or direct delivery. Date Delivered: 5-23-17 and specify direct delivery method: Mailed with water bill. Copy Posted at Town Hall - on Internet - Copy Available upon request
OR (mailing waiver option of the CCR itself) (Voided if using CCR for Tier III Public Notification!)

notify by "direct means" that the CCR is not being mailed, but it will be published in what newspaper(s) and when (attach copy of notice)
Date Delivered: _____ and specify "direct means" of delivery of the notice: _____

and the complete CCR was printed in the local newspaper(s)

and a copy of the CCR was made available upon request

Systems serving 500 or fewer persons must either distribute the CCR by mail or direct delivery.
Date Delivered: _____ and specify direct delivery methods: _____

OR (mailing waiver option of the CCR itself) (Voided if using CCR for Tier III Public Notification!)
 notify by "direct means" that the CCR is not being mailed, but how a copy may be obtained (attach copy of notice)
Date Delivered: _____ and specify "direct means" of delivery of the notice: _____

and a copy of the CCR was made available upon request

"Good faith" efforts (in addition to the above required methods) were used to reach non-bill paying consumers such as industry employees, apartment tenants, etc. Those extra efforts included the following methods:

- posting the CCR on the Internet at www.
- mailing the CCR to postal patrons within the service area
- advertising the availability of the CCR in news media (attach copy of announcement)
- publication of the CCR in local newspaper (attach copy)
- posting the CCR in public places such as: (attach list if needed) _____

delivery of multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers

delivery to community organizations such as: (attach list if needed) _____

Note: For the mailing waiver option, the "direct means" allowed are a letter, a bill stuffer, a door hanger, or a postcard dedicated to the CCR. The notice may not be on the water bill itself as the only means of notification.

Return this form to:
Public Water Supply Section, ATTN: CCR Rule Manager, 1634 Mail Service Center, Raleigh, NC 27699-1634